




GRATI POWER GENERATOR AND O&M SERVICE UNIT		Tanggal	2026-04-30	
PARAMETER	Perform	Units	Result	
			1	2
Motor Driven				
Waktu pencatatan			08:45	08:55
Suction Press	-	Psi	-	-
Discharge Press	175	Psi	175	175
Lube Oil level (L / N / F)	N	-	Normal	Normal
Diesel Engine				
Waktu Pencatatan			08:50	09:05
Engine Operating Hours	-	Hours	4.9	5.0
Battery I / II Voltage	12	Vdc	13.6	13.8
Battery I / II AMPERE	40	Amphere	0	0
Oil level dipstick	N	-	Normal	Normal
Fuel Level	17,5	Gal/Hr	17,5	17,5
Engine coolant level	N	-	Normal	Normal
Oil pressure	2.41 - 3.79	Bar	4	4
Air Filter	N	-	Normal	Normal
Exthouse System	N	-	Normal	Normal
Cooling Water Press	20-40	Psi	16	15
Coolant Temperature	70-93	C	44	56
Speed	2350	Rpm	2350	2350
Suction Press	-		-	-
Discharge Press	175	Psi	175	175
Fuel Temperature	-	C	36	43
Engine Torque	-	-	48	48
Persen Load	-	%	83	82
Flow Sea Water	-	USGPM	1000	1000

Press by Pass	-	Kg/Cm ²	10	10
---------------	---	--------------------	----	----

Keterangan : L : Low N : Normal H : Hight F : Full

Catatan : OK

SHIFT	K3	OPERATOR	SUPERVISOR
SHIFT B			
	Robeth Fafi R	Qodim	Didik H